

Testing laboratory HVAC

Test report No.: HP-07654-e

Objective: **Pressure loss measurements on air distribution system Roomair**

Client: **Roomair
Thurstrasse 14
CH-8501 Frauenfeld**

Date: **2007-12-11**



This report consists of 69 pages and may not be reproduced in abridged form without the explicit written permission of the **testing laboratory HVAC**.

Contents

1.1.	Summary air collection and distribution box, connecting pipe 90 mm	3
1.2.	Summary air collection and distribution box, connecting pipe 75 mm	4
1.3.	Summary supply and return air casing as distributor or collector, connecting pipe 90 mm.....	5
1.4.	Summary supply and return air casing as distributor, connecting pipe 75 mm	6
1.5.	Summary supply and return air, connecting pipe 90 mm	7
1.6.	Summary supply and return air casing, connecting pipe 75 mm	8
2.	Conclusion (Original test report p. 53).....	10



1.1. Summary air collection and distribution box, connecting pipe 90 mm

The resistance coefficient in the diagram refers to the exit speed w_2 at position 2.





1.2. Summary air collection and distribution box, connecting pipe 75 mm

The resistance coefficient in the diagram refers to the exit speed w_2 at position 2.





1.3. Summary supply and return air casing as distributor or collector, connecting pipe 90 mm

The resistance coefficient in the diagram refers to the exit speed w_2 at position 2.





1.4. Summary supply and return air casing as distributor, connecting pipe 75 mm



The resistance coefficient in the diagram refers to the exit speed w_2 at position 2.




1.5. Summary supply and return air, connecting pipe 90 mm



1.6. Summary supply and return air casing, connecting pipe 75 mm





2. Conclusion

As a precautionary action the flow distribution in the air distributors and air collectors has been looked at closely before starting the pressure loss measurements to find out if any balancing is needed. Preliminary measurements at different volume flows have shown that specifically for the pressure loss measurements of each unit under test no balancing is needed because the flow distribution in the distributors is even.

All the client's specifications outlined in the terms of reference have been met.

The measured results apply solely to the unit submitted for testing.

*Electronically recorded data will be stored for the duration of 3 years. The test report and any associated documents will be archived at the **testing laboratory HVAC** for the duration of 10 years.*

During this time the client may inspect these documents in situ. The costs of providing any copies that may be required will be charged to the client.

Horw, 2007-12-11

Andreas Odermatt, dipl. Ing. HTL
Deputy Manager, testing laboratory HVAC

Markus Lang, dipl. Ing. HLK FH
Scientific assistant